



NOTES:

1. VALVE BOX SHALL BE CENTERED OVER VALVE OPERATING NUT.
2. PVC EXTENSION SHALL BEGIN AS CLOSE TO VALVE AS POSSIBLE AND SHALL EXTEND TO WITHIN 6" OF GROUND SURFACE.
3. TOP OF VALVE BOX SHALL BE FLUSH WITH FINISH GRADE.
4. VALVE EQUIPPED WITH 2" SQUARE OPERATING NUT LOCATED WITHIN 24" FROM GROUND SURFACE. SEE VALVE OPERATOR EXTENSION DETAIL WHERE REQUIRED.
5. VALVES 12" AND SMALLER SHALL BE PROVIDED WITH CLASS B BASE PER SECTION 5.5.4. VALVES LARGER THAN 12" SHALL BE INSTALLED ON PRECAST CONCRETE PIER BLOCK.
6. NO PIPE JOINTS ALLOWED WITHIN 10' OF IN-LINE VALVES UNLESS JOINT RESTRAINT DEVICE PROVIDED.
7. ALL VALVES 12" AND LARGER SHALL BE BUTTERFLY VALVES.
8. ALL FITTINGS AND VALVES SHALL BE RESTRAINED PER MANUFACTURER'S RECOMMENDATIONS.



City of Amity
 109 Maddox Street
 Amity, Oregon 97101
 503.835.3711

STANDARD WATER VALVE
 SETTING DETAIL

DETAIL NO.

W-200

3/22/04