



ITEM	SIZE	DESCRIPTION	SPECIFICATION
1	AS REQ'D	SADDLE	FORD/ROMAC 202BS, 2" FIP TAP
2	2"	BALL CORP. STOP	MIP IN x FIP OUT; FORD FB1700-7, MUELLER B-20046, MCDONALD 3149B
3	2"	PJ ELL COUPLING	MIP x PEP PACK JOINT; FORD L84-77 ; MCDONALD 4779M-22
4	2"	PIPE	COPPER (TYPE K), 160 PSI, IPS FITTING COMPATIBLE, NSF 61
5	2"	PJ COUPLING	PEP PACK JOINT x MIP; FORD C84-77, MCDONALD 4753-22
6	2"	VALVE	AWWA C509 RESILIENT WEDGE GATE VALVE, THRD. ENDS, 2" NUT
7	AS REQ'D	EXTENSION	VALVE OPERATOR EXTENSION
8	N/A	VALVE BOX	VALVE BOX AND COVER
9	2"	NIPPLE	RED BRASS THRD. NIPPLE, 12" LONG
10	2"	TEE	BRONZE TEE W/ 2" THREADED PLUG, DRILL 1/8" HOLE FOR DRAIN
11	2"	PIPE	GALV. PIPE AS REQ'D.
12	2"	ELBOW/PLUG	GALV. MIP THRD. PLUG

NOTES:

USE ONLY WHERE APPROVED. GENERALLY LOCATED AT LOCAL LOW POINTS IN THE PIPING SYSTEM WHERE HYDRANT IS NOT PRACTICAL. HYDRANTS OR LARGER BLOW-OFF MUST ALSO BE LOCATED NEARBY TO ALLOW PROPER FLUSHING. MAY BE ALLOWED ON 6" MAINS WHERE LINE PRESSURE EXCEEDS 75 PSI.

 City of Amity 109 Maddox Street Amity, Oregon 97101 503.835.3711	<h2>2" BLOW-OFF ASSEMBLY</h2>	DETAIL NO.
		W-400
		3/30/04