



NOTES:

1. PROTECTION FROM FREEZING SHALL BE PROVIDED.
2. DCVAs MAY BE INSTALLED BELOW GRADE IN A BOX OR VAULT WITH BRASS OR PLASTIC PLUGS PROVIDED IN ALL TEST PORTS AND ASSEMBLY IS NOT TO BE SUBJECT TO CONTINUOUS IMMERSION.
3. DCVAs SHALL BE PROVIDED WITH ADEQUATE AIR-GAPPED DRAINAGE. DRAIN SHALL NOT BE CONNECTED TO SANITARY OR STORM DRAIN SYSTEMS.
4. LOCATE AS DIRECTED AS CLOSE TO MAINLINE CONNECTION AS POSSIBLE. GENERALLY LOCATED IMMEDIATELY AFTER WATER METER.
5. MAY BE INSTALLED VERTICALLY IF INTERNALLY SPRING LOADED, HAS NORMAL FLOW UPWARD, AND IS RECOMMENDED BY MANUFACTURER FOR VERTICAL INSTALLATION.
6. CLEARANCES SHALL ALSO APPLY WHEN INSTALLED INSIDE BUILDING.
7. SHALL NOT BE INSTALLED AT A HEIGHT GREATER THAN 5 FEET UNLESS THERE IS A PERMANENTLY INSTALLED PLATFORM MEETING OSHA STANDARDS TO FACILITATE SERVICING THE ASSEMBLY.
8. VAULTS SHALL BE SIZED ACCORDINGLY TO PROVIDE MINIMUM CLEARANCES. VAULTS SHALL BE PROVIDED WITH TRAFFIC RATED LIDS WHERE REQUIRED. VAULTS TO BE ARMORCAST OR APPROVED EQUAL.

WILKINS 3/4" 950XLT SHOWN WITH
 ARMORCAST P6001534X12 BOX AND
 A6001643-R LID



City of Amity
 109 Maddox Street
 Amity, Oregon 97101
 503.835.3711

**DOUBLE CHECK VALVE
 ASSEMBLY (3/4" - 2")**

DETAIL NO.

W-900

3/31/04